

May 8, 2007

CREST PRECAST, INC.
STEVE MADER
609 KISTLER DR
LA CRESCENT MN 55947-1721

Re: Description: GREASE INTERCEPTOR (also see SEWAGE TANKS)
Manufacturer: CREST PRECAST, INC.
Product Name: GREASE INTERCEPTOR
Model Number(s): 15000
(L.L. 80", 188.05 GAL/IN., 84" MAX. DEPTH OF BURY)
Product File No: 20070095

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of June 2012.**

This approval is contingent upon compliance with the following stipulation(s):

- This product is approved to use the following:
 - Two inch schedule 40 PVC cast in riser for electrical wiring.
 - Neenah Foundry gasketed access cover.
 - Bilco locking hinged access cover.
 - Pipe materials constructed in conformance with Table 84.30-2 or 84.30-11, Wis. Admin. Code poured into tank cover or access cover.
 - Four inch discharge opening in riser.
 - Dual inlets at end of tank with one access opening above both inlets.
 - Dual outlets at end of tank with one access opening above each outlet.
 - Side outlets for dose tanks.
 - Bottom and side pipe openings for siphon, pump and holding tanks.
 - Six, eight and ten-inch inlet and outlet openings.
 - Press Seal "Cast-A-Seal" and PSX Gasket System by Press Seal Gasket Corp., Polylok II High Pressure Pipe Seal by Polylok, and A-Lok X-Cel by A-Lok Products, Inc..
 - Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST; Engineering Consultant--Plumbing Product Reviewer
Commerce; Safety & Buildings Div.
PO Box 2658; 201 W Washington Ave.
Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456; E-mail: Jean.MacCubbin@wisconsin.gov